

March 14, 2019

CITY OF WICHITA, KANSAS

REQUEST FOR FORMAL BID NUMBER FB190038

ADDENDUM # 2

PUBLIC WORKS & UTILITIES DEPARTMENT/FLEET & FACILITIES DIVISION

DESCRIPTION:

Remove & Replace Doors and Windows at Kansas Aviation Museum


OPENING DATE: FRIDAY, MARCH 15, 2019, AT 10:00 A.M.

The following additions, deletions, and/or changes have been added to the specifications and made a part of this formal bid FB190038.

See Attached Addendum # 2 Items.

ALL BIDS RECEIVED ON THURSDAY, MARCH 14, 2019, BEFORE NOON WILL BE RETURNED WITH THIS ADDENDUM. IF YOUR BID IS NOT RETURNED AND YOU WANT IT BACK, PLEASE CALL THIS OFFICE (316) 268-4636.

Each vendor is required to acknowledge receipt of this Addendum by their signature affixed hereto and to file same with and attached to this bid.



for Melinda A. Walker  
Purchasing Manager

\*\*\*\*\*

The undersigned acknowledges receipt of this Addendum and the bid submitted herewith is in accordance with the information, instruction and stipulations set forth herein.

\_\_\_\_\_  
Date

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature of Company Representative

\_\_\_\_\_  
Print Name of Company Representative

\_\_\_\_\_  
Title

GLMV ARCHITECTURE, INC.  
1525 E. Douglas  
Wichita, Kansas 67211

LIMITED DOOR REPLACEMENT  
KANSAS AVIATION MUSEUM  
3350 GEORGE WASHINGTON BOULEVARD  
WICHITA, KS 67210

ARCHITECTS PROJECT 15033.18009

ADDENDUM 2

Wednesday, March 13, 2019

The original Specifications and Drawings for the Project noted above, dated January 25, 2019, are amended as indicated in this Addendum 2.

This Addendum consists of 1 page.

ITEM NO.

CHANGES TO PRIOR ADDENDA (Does Not Apply)

CHANGES TO BIDDING REQUIREMENTS (Does Not Apply)

CHANGES TO CONDITIONS OF THE CONTRACT (Does Not Apply)

CHANGES TO THE SPECIFICATIONS (Does Not Apply)

CHANGES TO THE DRAWINGS (Does Not Apply)

GENERAL INFORMATION

- |                |           |   |
|----------------|-----------|---|
| <u>ADD 2-1</u> | Question: | Existing doors are 2-inches thick and new hollow-metal doors are 1-3/4-inches thick. Is it the intention to use required hardware with existing frames or can the frames be replaced? |
|                | Answer:   | Hardware specifiers will need to be aware of the intention of replacing a 2-inch-thick door with a 1-3/4-inch-thick door. Field verify existing frames for hardware specification.    |
| <u>ADD 2-2</u> | Question: | Does the Project include any work on transoms above doors being replaced?   |
|                | Answer:   | Frames and transoms occurring above doors that are to be replaced shall be prepped and painted to match doors on both interior and exterior sides.                                    |

END OF ADDENDUM 2

GLMV ARCHITECTURE, INC.  
1525 E. Douglas  
Wichita, Kansas 67211

CONTROL TOWER WINDOW REPLACEMENT  
KANSAS AVIATION MUSEUM  
3350 GEORGE WASHINGTON BOULEVARD  
WICHITA, KS 67210

ARCHITECT'S PROJECT 15033.18010

ADDENDUM 2

Wednesday, March 13, 2019

The original Specifications and Drawings for the Project noted above, dated January 25, 2019, are amended as indicated in this Addendum 1.

This Addendum consists of 1 page.

ITEM NO.

CHANGES TO PRIOR ADDENDA (Does Not Apply)

CHANGES TO BIDDING REQUIREMENTS (Does Not Apply)

CHANGES TO CONDITIONS OF THE CONTRACT (Does Not Apply)

CHANGES TO THE SPECIFICATIONS (Does Not Apply)

CHANGES TO THE DRAWINGS (Does Not Apply)

GENERAL INFORMATION

ADD 1-1

Question: Will the carpet and vinyl base be replaced in the Tower?

Answer: The existing carpet and vinyl base in the Control Tower will be removed.

Carpet tile and adhesive will be provided, and the Contractor shall install.

The Contractor will need to provide and install the vinyl base.

END OF ADDENDUM 2