

January 9, 2018

CITY OF WICHITA, KANSAS

REQUEST FOR FORMAL BID NUMBER FB740233

ADDENDUM # 2

PARK & RECREATION DEPARTMENT/RECREATION DIVISION

DESCRIPTION: New Dugouts & Baseball Field Improvements at McAdams Park

OPENING DATE: FRIDAY, January 12, 2018, AT 10:00 A.M.

The following additions, deletions, and/or changes have been added to the specifications and made a part of this formal bid FB740233.

- 1. See Attached for Addendum #2 Items.

FOR BIDS SUBMITTED ONLINE ELECTRONICALLY (<https://ep.wichita.gov>): YOU NEED TO REVIEW, MAKE ANY NECESSARY CHANGES AND RESUBMIT YOUR BID. THE ADDENDUM WILL BE ACKNOWLEDGED WHEN YOU HAVE READ THE LEGAL BID ADDENDUM FORM.

ALL BIDS RECEIVED ON **January 9, 2018, BEFORE NOON** WILL BE RETURNED WITH THIS ADDENDUM. IF YOUR BID IS NOT RETURNED AND YOU WANT IT BACK, PLEASE CALL THIS OFFICE (316) 268-4636.

Melinda A. Walker
Purchasing Manager

The undersigned acknowledges receipt of this Addendum and the bid submitted herewith is in accordance with the information, instruction and stipulations set forth herein.

Date

Company Name

Signature of Company Representative

Print Name of Company Representative

Title

This Addendum is hereby made part of the Contract Documents to the same extent as though it were originally included therein.

All Contractors, Subcontractors and suppliers are reminded that they shall be familiar with all Addenda items (as well as all parts of the Construction Documents) so as to understand the extent of their work and its interrelation with other trades.

To all bidders for furnishing all labor and materials necessary for the following Contract:

**City of Wichita – McAdams Park -
New Dugouts & Field Improvements**

1329 E. 13th Street N.
WICHITA, KANSAS

Prepared by:
Schaefer Johnson Cox Frey Architecture, Inc.

GENERAL:

ITEM AD2-G01 PROJECT MANUAL, SPECIFICATIONS, Section 07 41 13 Metal Roof Panels:
CLARIFICATION: 2.04.A The color of the existing roofs is equivalent to "Regal Blue" by McElroy Metal, Inc.

ELECTRICAL:

ITEM AD2-E01 PROJECT MANUAL, SPECIFICATIONS, Section 01 23 00 Alternates:
REVISION: 1.04.A: Electrical shall generally be routed from each scoreboard to exterior electrical Panel "L" located south of the northeast field and east of the new restroom / concessions building. No trenching allowed through the ballfields.

