

Textron Aviation East Campus
B31 Air Compressor
PEC File No. 170696-000
February 27, 2018

ADDENDUM NO. 4

The original Project Manual and Drawings for the Project noted above, are amended as indicated on this Addendum 4.

GENERAL:

MECHANICAL:

1. Question: Spec section 221513 General Service compressed air calls for piping between compressor/dryer/tank to be sch40 welded steel, but distribution piping to be copper with brazed joints. Detail 2/M-601 shows 2" air posts to be welded to plate at floor. Please verify if 4" and 2" distribution piping past the receiver tank is to be copper or sch 40 steel.
 - a. Answer: Distribution piping past the receiver tank is to be schedule 40 steel.