
B0001474

ADDENDUM # 1

FROM: *Kim Sowell*

Campus Box 12

Ph: 316-978-3784

Fax: 316-978-3528

TO: All Bidders

DATE: 8/21/2017

NEW CLOSING DATE AND TIME: 8/24/2017 @ 2:00 PM

SUBJECT: B0001474 Addendum – WATC/NCAT Autoclave Addition

CHANGES TO BID:

- Refer to attachments for addendum detail.
- Revised Bid Form and new Signature Page attached. Complete these forms in their entirety when bidding the project.
- No new bid bond is required.

NO. OF PAGES (including cover sheet): 4

Bid Responses must be mailed or hand delivered (faxed and emailed responses are not allowed) to WSU Office of Purchasing prior to the bid closing date and time!

Wichita State University
Office of Purchasing
Kim Sowell
1845 Fairmount, Campus Box 12
Morrison Hall, Room 021
Wichita, KS 67260-0012
Phone: 316-978-3784
Fax: 316-978-3528

ADDENDUM NO. 2

August 21, 2017

ISSUED BY:

Wichita State University
1845 Fairmount St.
Wichita, Kansas 67260-0047

GLMV Architecture
1525 E. Douglas
Wichita, Kansas 67211
Contact: Matt Cortez, Vice President
Phone Number: 316-265-9367
E-Mail: mcortez@glmv.com

ISSUED BY ARCHITECT/ENGINEER
NOTICE ALL BIDDERS FOR THE:

Wichita State University
National Center for Aviation Training Autoclave Addition
4004 N. Webb Road
Wichita, Kansas 67226

You are instructed to read and to note the following described changes, corrections, clarifications, omissions, deletions, additions, approvals and statements pertinent to the Contract Bid and Construction Documents.

The Addendum No. 2 is a part of the Contract Bid and Construction Documents and shall govern in the performance of the Work.

General

Article 2-1, Insulated Metal Wall Panels

- A. The contractor shall remove and salvage all existing insulated metal wall panels noted to be removed on DEMO PLAN A/A-101. The contractor shall reinstall the existing insulated metal panels on new sub girt framing as noted on wall sections 2-4/ A501. The subgirts shall be attached over the 5/8" gypsum sheathing which shall be anchored to the metal studs per specification section 061600 SHEATHING and as listed in Addendum 1.
- B. After reinstalling the metal panels the owner and architect will review the technical and aesthetic integrity of the insulated metal wall panel assembly for final approval.

Specifications

Article 2-2, 074216 INSULATED –CORE METAL WALL PANELS

- A. Revise paragraph 1.6 QUALITY ASSURANCE, A. Installer Qualifications, to read as follows:
 - A. Installer Qualifications: An employer of workers who have proven experience removing and installing insulated core metal wall panels.

SIGNATURE SHEET

Item: **WATC/NCAT Autoclave Addition**

New Closing Date: **2:00PM, Thursday, August 24, 2017**

The undersigned acknowledges receipt of the following addenda to this Request for Quotation:

#1 #2 #3 #4 #5 #6 #7 #8 #9 #10 #11 #12

By submission of a bid and the signatures affixed thereto, the bidder certifies all products and services proposed in the bid meet or exceed all requirements of this specification as set forth in the request and that all exceptions are clearly identified.

State Tax: The undersigned attests this Bidder is not in arrears in taxes due the State of Kansas.

Legal Name of Person, Firm or Corporation _____

Mailing Address _____ City & State _____ Zip _____

Toll Free Telephone _____ Local _____ Cell: _____ Fax _____

Tax Number _____

CAUTION: If your tax number is the same as your Social Security Number (SSN), you must leave this line blank. DO NOT enter your SSN on this signature sheet. If your SSN is required to process a contract award, including any tax clearance requirements, you will be contacted by an authorized representative of the Office of Purchasing at a later date.

E-Mail _____

Signature _____ Date _____

Typed Name _____ Title _____

Items required with your Bid: The items below, that are checked, must be submitted with your bid for your offer to be considered responsive to the Request for Quotation. Please view the file posted on www.wichita.edu/purchasing, **WSU Bid Solicitations page**, **Boilerplate of Request for Quotation: Terms and Conditions/Bidding Instructions** for more information and clarifications to the submission of these required items.

Bid Bond or Guaranty (mandatory if a Performance and/or Public Works Bonds are required see terms and conditions)

Certificate of Insurance

References as required

Acknowledgement of all addenda

Proposed Timeline of project

Certification regarding Immigration Reform and Control

Mandatory Attendance at Pre-Bid Meeting

Other: _____