

Subject: Blast Freezer Door Replacement  
School Service Center

Owner: Unified School District #259  
Wichita, Kansas


**ITEM #1:** Per project drawings, the door openings are to remain 4' wide. The curtain is to be 7' wide.

**ITEM #2:** In the specifications on page 83300-3 HIGH PERFORMACE DOOR Section 2.01 Products ¶ G. Electrical Operations, replace 2b. with the following:

b. Power Supply:

1) Primary Voltage: Coordinate wiring requirements and current characteristics of door electrical system with building electrical system. Supply shall be rated at 480 volt, (3) phase, 60Hz, 20 amps.

This addendum shall be acknowledged by the bidder on E-Bid.



---

Luke Newman, Director  
Design and Construction  
USD 259