
B0001589

ADDENDUM # 1

FROM: *Kim Sowell*

Campus Box 12

Ph: 316-978-3784

Fax: 316-978-3528

TO: All Bidders

DATE: 4/19/2019

CLOSING DATE AND TIME: 4/25/2019 @ 2:00 PM

SUBJECT: B0001589 Addendum – Site Improvements Fairmount Tower Area

CLARIFICATIONS ADDITIONS TO BID SPECIFICATIONS:

QUESTION 1: Please clarify how much sag you require in the chain between posts. Detail 1 AS-101 indicate a lot of sag in the chain.

ANSWER 1: The chain center drop distance between steel pipe bollards shall be a maximum of 10”.

QUESTION 2: What grade of the chain are you requiring?

ANSWER 2: Chain type shall be galvanized ¼” - grade 30.

QUESTION 3: Detail 1 on AS-101 Please clarify your wanting the steel bollard and the top concrete dome painted black or wanting just the concrete dome painted black.

ANSWER 4: Clarification on detail 1/AS-101 shall read as follows:

4” sched. 40 steel pipe bollard with concrete domed top
shall receive one coat of alkyd primer and two coats of semi-gloss
Black alkyd enamel paint.

Pre-Bid Sign-in Sheet is attached.

NO. OF PAGES (including cover sheet): 3

Bid Responses must be mailed or hand delivered (faxed and emailed responses are not allowed) to WSU Office of Purchasing prior to the bid closing date and time!

Wichita State University

Office of Purchasing

Kim Sowell

1845 Fairmount, Campus Box 12

Morrison Hall, Room 021

Wichita, KS 67260-0012

Phone: 316-978-3784 and Fax: 316-978-3528

