

Subject: Office Renovation – Woodman Elementary School

Owner: Unified School District #259  
Wichita, Kansas

- ITEM #1:** ADDITION: SHEET A7.1, Cubicle Track and Curtain:
- a. Overhead surface-mounted extruded aluminum track, nylon carriers, and flameproofed fabric curtains.
  - b. Manufacturers: A. R. Nelson Co., InPro Corporation, or equal.
  - c. ~~Clear anodized track. Fabric color to be selected from manufacturer's~~ standard.
  - d. Submit product data for approval.

- ITEM #2:** ADDITION: SHEET A9.1, Dimensional Signage:
- a. Provide 10" high, ½" thick, powder-coated cast metal or flat-cut metal letters with metal stand-offs.
  - b. Manufacturers: Cosco Industries, InPro Corporation, or equal.
  - c. Provide wall blocking required.
  - d. Font and colors to be selected from manufacturer's standard range.
  - e. Submit product data and shop drawing for approval.

- ITEM #3:** REVISION: SHEET AS.3, 2.1 CERAMIC TILE, C. Glazed Wall Tile, Line 4:
4. Color to be selected from "American Olean, Bright & Matte Glazed" collection, price groups 3 and under. A field tile color will be selected, and an accent bullnose tile will be selected for the tile row at the top of the wainscot. There will be no other pattern.

- ITEM #4:** REVISION: SHEET AS.3, 2.1 CERAMIC TILE, F. Porcelain Tile at Vestibule" Add Line 2:

2. Size to be 8" x 8"

- ITEM #5:** ADDITION: SHEETS D1.0 and A1.1, add the following:

1. Existing painted tile mosaic above door 102A shall remain.
2. Existing wall plaque on brick where door 102B occurs shall be protected and relocated. Coordinate new location with architect.

**ITEM #6:** ADDITION: SHEET ED2.1, add the following:

1. Contractor shall relocate existing fire alarm strobe device located on east wall of existing Nurse Room. The fire alarm device is located on the corridor side of the wall and shall be relocated as required. Contractor shall provide additional wiring and surface mounted raceways as required.

---

**ITEM #7:** ADDITION: SHEET AS.2, Section 08110: Add Mesker as an approved manufacturer.

This addendum shall be acknowledged by the bidder on the Bid Form.



---

Kenny Saldana  
Design & Construction  
USD 259