


Subject: Office Renovation – Woodman Elementary School

Owner: Unified School District #259
Wichita, Kansas

- ITEM #1:** REVISION: SHEET AS.1, Section 06402: AWI certificate is not required for this project.
- ITEM #2:** DELETION: SHEET AS.1, Section 06402 – 1.1 SECTION REQUIREMENTS: Item C is to be deleted.
- ITEM #3:** DELETION: SHEET AS.2, Section 08211 – 1.1 SECTION REQUIREMENTS: Item D is to be deleted.
- ITEM #4:** CLARIFICATION: SHEET A1.1, DOOR SCHEDULE: Doors identified as “20/45” indicate that the doors shall be 20-minute fire-rated and the door frame is 45-minute-rated. No label is needed for the frame. However, the doors need to include a 20-minute label.

This addendum shall be acknowledged by the bidder on the Bid Form.


Kenny Saldana
Design & Construction
USD 259