
B0001688

ADDENDUM # 3

FROM: *Kim Sowell*

Campus Box 12

Ph: 316-978-3784

Fax: 316-978-3528

TO: All Bidders

DATE: 03/18/2021

CLOSING DATE AND TIME: 03/23/2021 @ 2:00 PM

SUBJECT: B0001688 Addendum – Lindquist Hall Electrical Distribution Replacement and Restroom Remodel

CLARIFICATIONS AND ADDITIONS TO BID:

- See attachments for addendum details.

NO. OF PAGES (including cover sheet): 2

Bid Responses must be emailed to kim.sowell@wichita.edu prior to the bid closing date and time! Hand delivered or mailed responses are not allowed to WSU Office of Purchasing.

Wichita State University
Office of Purchasing
Kim Sowell
1845 Fairmount, Campus Box 12
Jardine Hall, Room 201
Wichita, KS 67260-0012
Phone: 316-978-3784

STATE OF KANSAS
CONSTRUCTION PROJECT NO. A-014205

ADDENDUM 3

March 18, 2021

ISSUED BY:

Wichita State University
1845 Fairmount Street
Wichita, Kansas 67260-0047

GLMV Architecture
1525 E. Douglas
Wichita, Kansas 67211
Contact: Meredith Hampton
Phone Number: 316-265-9367
E-Mail: Meredith.hampton@glmv.com

ISSUED FOR ARCHITECT/ENGINEER
NOTICE ALL BIDDERS FOR THE:

Wichita State University
WSU Lindquist Hall Electrical Distribution Replacement and Restroom Remodel
Wichita, Kansas

You are instructed to read and to note the following described changes, corrections, clarifications, omissions, deletions, additions, approvals and statements pertinent to the Contract Bid and Construction Documents.

The Addendum 3 is a part of the Contract Bid and Construction Documents and shall govern in the performance of the Work.

Article 1.1, Clarification

- A. Clarification: At all Men's and Women's Restroom doors (9 total) provide new 3'x7' solid wood door and transom. 20 min rated with new hardware. Provide rabbeted edge at top of door/bottom of transom as required for new smoke seal. Field verify exact dimensions of openings. Stain door to match existing.

Drawings (Does Not Apply)

END OF ADDENDUM 3